



Department of Energy

Ohio Field Office
Fernald Area Office

P. O. Box 538705
Cincinnati, Ohio 45253-8705
(513) 648-3155



JUN 6 1997
DOE-1030-97

Mr. James A. Saric, Remedial Project Director
U.S. Environmental Protection Agency
Region V-SRF-5J
77 West Jackson Boulevard
Chicago, Illinois 60604-3590

Mr. Tom Schneider, Project Manager
Ohio Environmental Protection Agency
401 East 5th Street
Dayton, Ohio 45402-2911

Dear Mr. Saric and Mr. Schneider:

IMPLEMENTATION OF OPERABLE UNIT 5 RECORD OF DECISION - TREATMENT OF DISCHARGES - FERNALD ENVIRONMENTAL MANAGEMENT PROJECT


Reference: Letter DOE-0529-96, J. Reising to J. Saric and T. Schneider, "Implementation of Operable Unit 5 (OU5) Record of Decision - Treatment of Discharges at the Fernald Environmental Management Project," dated February 16, 1996.

Pursuant to Section 9.1.5 of the Operable Unit 5 (OU5) Record of Decision (ROD), the Fernald Environmental Management Project (FEMP) is required to provide written notification to the Ohio Environmental Protection Agency (OEPA) and U. S. Environmental Protection Agency (U.S. EPA) within seven days of initiating a bypass of stormwater directly to the Great Miami River. Information requirements for this notification were defined in the reference.

The FEMP initiated a stormwater bypass at 12:30 a.m., local time, on June 1, 1997, which lasted until 11:30 p.m. local time on June 3, 1997. A total of 2,765,000 gallons of stormwater was bypassed during this period. This bypass was necessary to mitigate the overflow of the Stormwater Retention Basins (SWRB). The SWRB overflow to Paddys Run, via the Storm Sewer Outfall Ditch, lasted from 3:30 a.m. June 1, 1997, until 5:50 p.m. on June 1, 1997. A total of 1,318,000 gallons of stormwater overflowed the SWRB during this time.

If you have any questions regarding our implementation of these requirements, please contact John Kappa at (513) 648-3149.

Sincerely,



Johnny W. Reising
Fernald Remedial Action
Project Manager

FEMP:Kappa

cc:

N. Hallein, EM-42/CLOV
G. Jablonowski, USEPA-V, 5HRE-8J
R. Beaumier, TPSS/DERR, OEPA-Columbus
M. Rochotte, OEPA-Columbus
F. Bell, ATSDR
D. S. Ward, GeoTrans
R. Vandegrift, ODOH
R. Geiger, PRC
D. Brettschneider, FDF/52-5
D. Carr, FDF/9
T. Hagen, FDF/65-2
J. Harmon, FDF/90
E. Henry, FDF/52-5
W. Hertel, FDF/52-5
M. Jewett, FDF/52-5
F. Johnston, FDF/52-5
J. Hughes, FDF/52-5
C. Little, FDF/2
AR Coordinator/78
EDC, FDF/52-7